

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 1452-1200:113 Page 1 of 1

CATEGORY: Floor-to-Floor/Floor-to-Wall Joint Systems

LISTEE: Hilti, Inc., 5400 S. 122nd East Ave, Tulsa, OK 74146
Contact: *Jonathan W. Matthews (918) 252-6181 Fax (918) 254-1679

DESIGN: Type CP601s Elastomeric Firestop Sealant for use in floor-to-floor and floor-to-wall joint systems. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	System No.	Assembly Rating
	FF-D-1011	3 Hr.
	FW-D-1011	3 Hr.

INSTALLATION: In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as firestop spray for use in floor-to-floor and floor-to-wall joint system when constructed and installed in accordance with UL Fire Resistance Directory. Approved systems:

FF-D-1011 and FW-D-1011

NOTE: Not approved for use in Head-of-Wall or Wall-to-Wall joint systems.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**